



Tea Board India

(Under Ministry of Commerce & Industry, Dept. of Commerce, Govt. of India)

14, B.T.M Sarani (Brabourne Road), Kolkata- 700 001

Website: www.teaboard.gov.in

e-Mail: secytboard@gmail.com

Phone No. +91 33 2237 1161

CORRIGENDUM-1

Amendments in respect to the Tender for design, fabrication, shop testing, supply, installation Site testing and commissioning of VRF/ VRV air conditioning system at Auditorium, Canteen, AHU room at First Floor and 6th floor at Tea Board, Head Office, Kolkata.

Tender Reference Number : 23(3)/Estt/2020/Part-II

Tender ID : 2020_TBI_546920_1

Points raised by the Bidders	Clarifications
OUT DOOR UNIT	This description shall include Variable Refrigerant Temperature (VRT) Smart technology or equivalent technology.
OUT DOOR UNIT	The external Static Pressure of the outdoor unit should be 60 Pa onwards.
Air Handling Unit	The make of the AHU should be Edgetech or Zeco
Air Handling Unit	The AHU should be 4 row/ 6 row deep DX cooling coil.
Air Handling Unit	The capacity of the AHU to be 30 TR for 38 HP outdoor unit and 25 TR for 30 HP outdoor unit
Refrigerant Pipe	The following dimensions of the refrigerant pipes to be included along with the existing dimensions : A. 28.6 mm B. 31.75 mm C. 41.00 mm
Payment Terms	The payment of 60% advance to be made to the supplier immediately after supply of materials and the rest 40% after completion of the work.

Sd/-
(Dr. Rishikesh Rai)
Secretary