



Tea Board India

(Under Ministry of Commerce & Industry, Dept. of Commerce, Govt. of India)

14, B.T.M Sarani (Brabourne Road), Kolkata- 700 001

Website: www.teaboard.gov.in

e-Mail: secytboard@gmail.com

Phone No. +91 33 2237 1161

CORRIGENDUM-3

Tender No. 23(13)/Estt/2019

Dated: 18th December, 2019.

CPP Portal Tender ID: 2019_TBI_528494_1

Corrigendum No. 3 reg. clarification in respect to Tender for Renovation of Toilet, Guest House Suit, Damp Proof, Water Pump repair and Replacement, Iron Removal Filter repairing, Drain Pipe replacement, Toilet Pipe Replacement and Repairing of Electrical Connections at quarter number two at Tea Board Staff Quarter, Salt Lake, GE Block, Sector- III, Kolkata

The following details may kindly be noted while filling-up the BoQ.

Sl. No.	Item Description	Quantity	Unit
4. (of BoQ)	Dismantling of old wash Basins and old pipe line. Install new UPVC water line (Hot & Cold). New pedestal type wash basin of ceramic material (colour should be as per choice) (preferably Ivory Colour) with specifications 23" x 18", Height of Pedestal : 27.5" with pillar cock. The basins should be fitted with Quality Plastic PVC drain pipe with accessories such as lock hook etc with a bib cock. The basin should also be fitted with Pressurized deck mounted nickel plated tap with "Aerator" to save water uses along with the water connection from the main line to the tap. Make: Essco, Jaquar, Hindware	9	Nos
6. (of BoQ)	Fixing of electrical connections and provide 1 nos of 18W LED light with Frame in each bathroom as per requirement also fixing of mirror light (7W LED with frame) along with electrical wiring, switch, exhaust fan-1 nos (10" diameter), supply of 1no of 6 ltr capacity Geyser at Suit of Guest House (Five star rating Heater of Havells / Ramington / Bajaj/Venus make) etc including taking out of the existing wiring and fixing the new lines with labour and material charges.	9	Nos
15. (of BoQ)	Repairing of the water pump (7.5 HP centrifugal) -1no and replacement of the one number of 7.5 HP centrifugal pump with 4 HP Submersible water pump fixing it in the existing ground water tank by suitably making provision by sinking a 8" dia high grade PVC heavy duty pipe of 1.5 meter length at the bottom of the existing water tank and pipe work providing connection from the existing water pipe to the pump including supply and installation of three phase bore well pump starter and repairing of the existing wirings. Make of 7.5 HP Pump and 4 HP submersible water pump: Crompton, Kirloskar, CRI	1+1	Nos

Sd/-
(Dr. Rishikesh Rai)
Secretary